

# Preliminary Assessment Report

## Project 6423807, 2403 BOYER AVE E

---

**Assessment Completed:** 7/25/2014

**Project Description:** Demolish existing single family residence and construct one new single family residence with attached garage.

**Primary Applicant:** [Andrew Novion](#)

This report lists the results of a preliminary assessment of your project requirements by various city departments. It's based on the project characteristics described on your site plan and preliminary application form. If your project required a pre-application site visit (PASV), the results of that site visit are also included. The goal of this report is to help you create a complete submittal package and reduce the need for corrections once your application has been submitted.

### Next Steps

1. Review the requirements in this report and contact the staff members listed below with questions.
2. If a street improvement plan is required, develop and submit it to the Seattle Department of Transportation (SDOT). **The Department of Planning and Development (DPD) will not accept your permit application until your street improvement plan is approved as 60% complete by SDOT. See [SDOT Client Assistance Memo 2213](#) for guidance about the 60% complete approval process.**
3. Schedule an appointment for permit application intake with DPD. **Please bring a copy of this report to your intake appointment.**

### Questions About This Report

If you have questions about the information in this report, contact the appropriate city staff member for each section.

#### DPD Drainage Requirements

Ede M Courtenay, (206) 733-9679, [Ede.Courtenay@seattle.gov](mailto:Ede.Courtenay@seattle.gov)

#### DPD Land Use Requirements

Arthur J Pederson, (206) 684-0638, [art.pederson@seattle.gov](mailto:art.pederson@seattle.gov)

#### DPD Preapplication Site Visit Requirements

Kathleen H Wilson, (206) 233-7932, [Kathleen.Wilson@seattle.gov](mailto:Kathleen.Wilson@seattle.gov)

#### Seattle City Light Requirements

Ray Ramos, (206) 615-1193, [ray.ramos@seattle.gov](mailto:ray.ramos@seattle.gov)

#### Seattle Department of Transportation Requirements

Yohannes Minas, (206) 733-9044, [yohannes.minas@seattle.gov](mailto:yohannes.minas@seattle.gov)

#### Seattle Public Utilities Requirements

Lan Chau

#### Water Availability

P Kimani, [Karen.Younge@Seattle.Gov](mailto:Karen.Younge@Seattle.Gov)

## Other Resources

- General questions about the permit process: Contact the DPD Applicant Services Center (ASC) at 206-684-8850.
- User-friendly guides to city permitting processes: [DPD](#) and [SDOT](#).
- [Detailed zoning information](#).
- Visit our [permit type pages](#) for step-by-step instructions and forms for preparing your application and plans for review.

## Requirements

### **DPD Drainage Requirements**

The following requirements are based on the current stormwater and side sewer codes.

#### **Existing Public Drainage Infrastructure**

Sanitary sewer main location: Boyer Ave E

Sanitary sewer main size: 10"

Storm drainage main location: Boyer Ave E

Storm drainage main size: 12"

#### **Drainage**

The drainage point of discharge (SMC 22.805.020) is located at: Public storm drain system.

#### **Permanent and Temporary Dewatering**

The footing drain (if part of building plan) point of discharge ([DPD DR 4-2011](#)) is located at the following:  
Public storm drain system.

### **DPD Land Use Code Requirements**

#### **Street Requirements**

Based on the scope of the proposed project, the following street improvements are required per Chapter 23.53 of the Seattle Municipal Code. Please review Right-of-Way Improvements Manual for design criteria (<http://www.seattle.gov/transportation/rowmanual/manual/>). Show required street improvements on your "enhanced site plan" at DPD permit application intake. If an SDOT Street Improvement Plan (SIP) is required, please list SDOT project number and SDOT contact name on the enhanced site plan. Street Improvement Plans must be accepted by SDOT prior to DPD permit application intake.

#### **DELMAR DR E**

Based on the documents provided, no street improvements are required per SMC 23.53.015 and SMC 23.53.006

#### **Land Use**

Based on the project scope and/or location of environmentally critical areas on the development site, SEPA may be required. See CAM 208 for more details.

Preliminary screening of your project has been completed and it appears that your proposal is located in an environmentally critical area (ECA) which may require an ECA review and SEPA. For additional information about ECAs and SEPA, visit the DPD website (<http://www.seattle.gov/dpd/Codes/>).

Based on the preliminary scope, the project may qualify for a specific exemption under the Environmentally Critical Areas Ordinance. Application and decision on the exemption must be made before submittal of a application. See CAM 327 for more details.

An arborist report may be required. See CAM 242 for more detail.

#### **Notes to Applicant**

Depending on actual extent of the proposal's new footprint or intrusion into ECA's or their buffer, other ECA reviews may be required. An arborist report for an assessment of any proposed removal or encroachment of an exceptional tree or trees in an ECA would be required.

### **Pre-Application Site Visit (PASV) Requirements**

PASV report requirements may be subject to additions, changes, or modifications by the department. The purpose of the report is to alert the applicant that there may be unusual or complex site conditions that trigger requirements from the department regarding this project. **The applicant is responsible for providing all required documents at the intake appointment.** If you have questions about this report or the PASV process, please contact the DPD Site Development Team at (206) 684-8860.

**Note:** Any project application associated with the development site can utilize the results from this PASV if the application is accepted by DPD within 24 months of the above inspection date. After 24 months, the applicant must apply for another PASV. No extensions will be granted.

The site plan did not include the following existing or proposed elements:

There is no access from Boyer Ave E.

### **ECA Mapping Unit and Type**

This project site appears to include the following ECAs and/or buffers:

Steep slope

Potential slide

### **Earth Disturbance**

If excavation has the potential to encroach on adjacent property in order to facilitate construction activity, please provide documentation of consent from the adjacent property owner. Show area of proposed encroachment on the submitted drawings and detailed cross-sections.

If temporary cuts greater than 1h:1v will be required in order to facilitate construction activity, please provide a geotechnical engineer's verification that soil conditions allow cuts to stand unsupported. Include detailed cross sections.

Please show all existing and proposed retaining walls/rockeries and the exposed height.

If shoring will be required, please provide submittals by geotechnical and structural engineers and show the proposed system on the submitted drawings. Include detailed cross sections.

### **Potential Impacts to Seattle Parks Property**

No parks property in vicinity

### **Tree Protection**

Trees greater than 6 inches in diameter as measured 4.5 ft above ground are present on the site but not shown on the site plan. Show the dripline of

- 1) **all** trees on the site,
- 2) adjacent trees that encroach on the site that are greater than 6 inches in diameter as measured 4.5 ft above ground, and
- 3) **all** trees located in the adjacent ROW.

Include common and scientific names for all trees shown. For more information, see [Director's Rule 16-2008](#) and [Tip 242](#).

### **Construction Stormwater Control**

All projects with earth disturbance, regardless of size, require temporary and permanent stormwater control in accordance with the Construction Stormwater Control (CSC) Technical Requirements Manual ([DR 16-2009, Volume 2](#)).

**Show the following on the [Construction Stormwater Control and Soil Amendment Standard Plan](#):**

Place compost socks, compost berms, filter fabric fencing, straw bales, straw wattles, or other approved perimeter control BMPs to eliminate construction stormwater runoff.

Show the location of a stabilized construction access to the site; show methods to eliminate uncontrolled conveyance of mud and dirt into the right of way (ROW).

Cover bare soil with compost blankets, straw, mulch, matting, or other approved equal to control construction stormwater runoff.

Cover stockpiles and bare slopes with compost blankets, tarps, matting or other approved equal to control construction stormwater runoff.

A First Ground Disturbance inspection is required before any ground disturbance related to this permit, including demolition, tree cutting, clearing, grubbing, and grading. After your permit is issued, schedule an inspection by calling (206) 684-8900 or [online](#) at <http://web1.seattle.gov/DPD/InspectionRequest/default.aspx>.

### **Inspectors Notes**

There is no access from Boyer Ave E, and access from Delmar Dr E is via an unimproved, one-lane gravel alley. It appears there will be conflicts with delivery of construction materials and equipment, and vehicle access.

## **Standard Submittal Requirements for Projects in an ECA**

Submit a geotechnical report with the permit intake submittal package. Geotechnical report must be signed and stamped by a geotechnical engineer licensed in the State of Washington per [SMC 22.170.070](#), [SMC 25.09](#), and [Directors Rule \(DR\) 18-2011](#).

Provide a topographic survey with 2-foot contours on and within 25-feet of the property, stamped by a licensed land surveyor (see [25.09.330A](#))

Delineate the clearing limits on the site plan

Provide a vegetation restoration plan per SMC [25.09.320](#), [Tip 331](#) and [Tip 331A](#). **Prior to any vegetation removal in the critical area, review, approval, and a preconstruction meeting is required**

Delineate the steep slope critical area on a site plan based on the survey (per SMC 25.09.020 A3b(5)).

Provide area calculations for the steep slope delineation.

Show the steep slope buffer. Generally, the buffer is 15-feet from the top and/or toe of the slope

Construction activity area appears to be within the steep slope critical area and/or its associated buffer. A steep slope variance may be required (see SMC 25.09.180E.1)

## **Seattle City Light Requirements**

### **Easements**

SCL power easement is required. Property survey may be required at project's expense. The future LBA as shown on the site plan will require a City Light easement

Other requirements: At the time of this review, SCL has not received or reviewed an application for short subdivision or lot boundary adjustment. The parent parcel is considered one site and SCL's single-service rule applies. Please contact your Electrical Service Representative well in advance of construction for clarification and electrical service advice.

### **Notes to Applicant**

For new service, please contact the Electrical Service Representative for your area several months before new service is required to determine your electric service design, service location and what kind of service is available at the building site. An Application for Electrical Service must be submitted to Seattle City Light. The Electrical Service Representative should also be contacted to coordinate electrical disconnections prior to demolition and temporary power for construction. Your Electrical Service Representative is: Jason Chollette, 206-684-4977, [jason.chollette@seattle.gov](mailto:jason.chollette@seattle.gov). Be advised that it is the applicant's responsibility to seek guidance from SCL. Failure to contact SCL at your earliest convenience could severely impact your project's scope, schedule and budget. This responsibility rests solely with the applicant.

## **SDOT Requirements**

Based on the information provided at this time, it appears that no street improvements are **required**. All work in the right-of-way requires a permit. Therefore, if you are planning discretionary improvements you should contact SDOT as soon as possible. Be advised that it is the applicant's responsibility to seek guidance from SDOT Street Use should the scope of the project change, or should the applicant become aware of proposed construction in the ROW. Failure to contact SDOT at your earliest convenience could severely impact your project's scope, schedule and budget. This responsibility rests solely with the applicant.

## **SPU Requirements**

### **Water Availability**

Your water availability assessment has been waived.

For all multifamily, commercial, and industrial properties, the requirements for solid waste storage and pickup are outlined in SPU CAM 1301, available on the web at:

[http://www.seattle.gov/util/stellent/groups/public/@spu/@csb/documents/webcontent/cos\\_004542.pdf](http://www.seattle.gov/util/stellent/groups/public/@spu/@csb/documents/webcontent/cos_004542.pdf). For questions about solid waste requirements, contact Liz Kain, (206) 684-4166, [Liz.Kain@seattle.gov](mailto:Liz.Kain@seattle.gov).

### **Other Requirements**

## **Other Requirements**

Owners of residential property occupied by a tenant who will be displaced by housing demolition, substantial rehabilitation, change of use, or removal of use restrictions may need to obtain a Tenant Relocation License. Refer to DPD Tip 123, Seattle's Tenant Relocation Assistance Ordinance, for further information and instructions or call (206) 684-7979.

If your project involves additions or modification to or demolition of an existing building that contains four or more dwelling units or 4,000 square feet or more of non-residential area, and the building is a designated historic landmark or is 50 years old and meets the criteria set forth in SMC 25.12 for landmark designation, SEPA is required. Please contact the Department of Neighborhoods at (206) 684-0228 or [www.seattle.gov/neighborhoods/preservation](http://www.seattle.gov/neighborhoods/preservation) to determine if your building is a designated landmark or if a referral is necessary to determine if the building meets the criteria in SMC 25.12. Refer to Tip 208 for information regarding the application requirements for a SEPA review and Tip 3000 for information regarding landmarks and historic preservation.

If the scope of your proposed project changes before your DPD intake appointment or SDOT street improvement plan application, the requirements in this report may change. If there are municipal code and ordinance changes before our DPD intake appointment, the project must meet the new code requirements. Additional street improvement requirements may be triggered if a permit application for a development project on adjacent property is also undergoing review.

Please be aware that all persons or companies working within the City limits, including all contractors, subcontractors, permit expeditors and other service providers are required to possess a valid City of Seattle business license. This license is required in addition to any other licenses required by the State of Washington, such as a contractors' license or state business license. For more information about City of Seattle business licenses, please contact inspector Michale Crooks at 206-684-8871, [Michale.Crooks@seattle.gov](mailto:Michale.Crooks@seattle.gov), or visit the [Licensing and Tax Administration Division website](#).